

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: [info@gslabs.com](mailto:info@gslabs.com)  
Internet: [www.gslabs.com](http://www.gslabs.com)

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037

## REPORT OF ANALYSIS

REPORT # 391014008.0

CLIENT # HAR134

DATE SUBMITTED: 10/14/2019

TO: Harbor School  
2210 West County Line Road

Jackson NJ 08527  
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: OFFICE FILTER, HARBOR SCHOOL, 240 BROAD ST.,  
EATONTOWN, NJ. 07724

DATE SAMPLED: 10/12/2019

TIME SAMPLED: 09:06

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	10/23/19-17:07
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjddep.html](http://www.gslabs.com/certnjddep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405512

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gslabs.com  
Internet: www.gslabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
REPORT # 391014004.0

TO: Harbor School  
2210 West County Line Road

CLIENT # HAR134  
DATE SUBMITTED: 10/14/2019

Jackson NJ 08527  
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE  
SAMPLE ID: FIRST DRAW - FIELD BLANK  
SAMPLE LOCATION: HARBOR SCHOOL, 240 BROAD ST., EATONTOWN, NJ. 07724

DATE SAMPLED: 10/12/2019 TIME SAMPLED: 08:38

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	10/23/19-16:56
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gslabs.com  
Internet: www.gslabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
**REPORT # 391014007.0**  
**CLIENT # HAR134**

**DATE SUBMITTED: 10/14/2019**

**TO: Harbor School**  
**2210 West County Line Road**

Jackson  
ATT: Mark Costa

NJ 08527

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: OFFICE TAP, HARBOR SCHOOL, 240 BROAD ST., EATONTOWN,  
NJ. 07724

DATE SAMPLED: 10/12/2019

TIME SAMPLED: 08:57

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	10/23/19-17:04
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405512

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gsllabs.com  
Internet: www.gsllabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
REPORT # 391014006.0  
CLIENT # HAR134

DATE SUBMITTED: 10/14/2019

TO: Harbor School  
2210 West County Line Road

Jackson  
ATT: Mark Costa

NJ 08527

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: NURSE OFFICE SINK, HARBOR SCHOOL, 240 BROAD ST.,  
EATONTOWN, NJ. 07724

DATE SAMPLED: 10/12/2019

TIME SAMPLED: 08:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	0.001	ug/l	15	10/23/19-17:01
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



405512

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 Email: info@gsllabs.com  
 Internet: www.gsllabs.com

Main Lab  
 410 Hillside Avenue  
 Hillside, New Jersey 07205  
 NJDEP Lab Cert. #20044

Jersey Shore Lab  
 54 Main Street  
 Waretown, New Jersey 08758  
 NJDEP Lab Cert. #15037  
**REPORT # 391014005.0**  
**CLIENT # HAR134**

**REPORT OF ANALYSIS**

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director  
 Jordan B. Klein, B.A., Exec. Vice President  
 Sharon Ercoliani, B.A., Laboratory Manager

TO: Harbor School  
 2210 West County Line Road

DATE SUBMITTED: 10/14/2019

Jackson NJ 08527  
 ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: BASEMEMNT STOVE SINK, HARBOR SCHOOL, 240 BROAD ST.,  
 EATONTOWN, NJ. 07724

DATE SAMPLED: 10/12/2019

TIME SAMPLED: 08:43

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	10/23/19-16:59
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405512

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.